

Sanitation Committee
August 12, 2026
4:30 PM

Present: Matt Crull, Bob Griffith, Steve Engberg(by phone), Joe Taylor, Drew Schumacher, John Boecker, Jim Warner, Shelbi Swinscoe

Absent:

Called meeting to order at 4:30 PM

Review WWTP Blower Quotes

John Boecker, Wastewater Treatment Plant Operator, presented quotes for replacement and repair of blowers at the Wastewater Treatment Plant. Boecker reviewed the condition of the existing equipment and discussed options for maintaining reliable operation of the aeration system.

Based on the quotes received and the current condition of the equipment, Boecker recommended rebuilding one existing blower and purchasing one new blower. Following discussion, the Committee approved moving forward with the recommended option.

Open Forum

Matt Crull commended John Boecker and Chris Ellington for their dedication and work at the Wastewater Treatment Plant. Committee members expressed appreciation for their efforts in maintaining plant operations.

Jim Warner presented information regarding sewer televising and inspection efforts for South Walnut Street, South Harrison Place, and the Cherry/Shaeffer neighborhood. Warner reviewed the areas identified for camera inspection and discussed the benefits of evaluating the condition of the sewer infrastructure to assist with future maintenance and project planning.

Adjourned.

Prepared by _____ Date _____

Approved by _____ Date _____